

	SUB DIVISION	FCAA APPROVED HYDRANT LOCATION	DATE TO ENGINEERING FOR DRAWINGS	ENGINEERING DRAWINGS COMPLETE	DATE TO FDOT APPROVAL (if Required)	FDOT PERMIT APPROVAL	FCAA UTILITY PERMIT (Good for 1 year)	DATE TO CONTRACTOR FOR INSTALLATION	COMPLETE
161212 The Performance Bond was received from La Rocco; 161114 ILA is pending BOCC Approval; 161017 Selection of Vendor & Contract Submitted to Board for approval; 160919 RFP Submitted to Board for approval; 160822 Awaiting FDOT approval Central/US 1 hydrant; 160712 FDOT road approval									
Central & US 1 ... Feasible on US #1 - Permit still pending as of 10/12/17	Hibiscus	Approved	04/16/2016	06/07/2016		FDOT APPROVED 11/02/16	Application submitted Wk of 160627		
Largo Road & Big Pine Road ... Place on Largo	Pamela Villa MM 102 Ocean side	Approved	04/16/2016	06/07/2016		N/A	Application submitted Wk of 160627		
Largo Road & Bahia Honda Road ... Place on Largo	Pamela Villa MM 102 Ocean side	Approved	04/16/2016	06/07/2016		N/A	Application submitted Wk of 160627		
Largo Road & Vaca Road . . . Place on Vaca	Pamela Villa MM 102 Ocean side	Approved	04/16/2016	06/07/2016		N/A	Application submitted Wk of 160627		
Cactus & Thomas Avenue Feasible 6" water main on both streets (Moved from Phase 4)	Rock Harbor	Approved	04/16/2016	06/07/2016		N/A	Application submitted Wk of 160627		
Michelle & Judy (Moved from Phase 4)	Largo Gardens	Approved	04/16/2016	06/07/2016		N/A	Application submitted Wk of 160627		
U.S. 1 & Lignumvitae Drive ... Place in US #1	Pamela Villa MM 102 Ocean side	Approved	04/16/2016	06/07/2016		N/A	Application submitted Wk of 160627		
Mahogany & Oleander ... Place on Mahogany	Pamela Villa MM 102 Ocean side	Approved	04/16/2016	06/07/2016		N/A	Application submitted Wk of 160627		
Collins Street & Village Drive ... Place on Collins	Angler's Park MM 103.4 Ocean	Approved	04/16/2016	06/07/2016		N/A	Application submitted Wk of 160627		
Sound Drive & Plante Street ... Place on Sound	Angler's Park MM 103.4 Ocean	Approved	04/16/2016	06/07/2016		N/A	Application submitted Wk of 160627		
Snapper & Blue Runner l ... Place on Snapper	Largo Sound Park MM 103.4 Ocean	Approved	04/16/2016	06/07/2016		N/A	Application submitted Wk of 160627		
Kingfish & Se Marlin Ave ... Place on Marlin	Largo Sound Park MM 103.4 Ocean	Approved	04/16/2016	06/07/2016		N/A	Application submitted Wk of 160627		
Barracuda between Bluerunner and Turbot. Water main is on north lane (exit to US1).	Largo Sound Park MM 103.4 Ocean	Approved	04/16/2016	06/07/2016		N/A	Application submitted Wk of 160627		
672 Dolphin Avenue	Angler's Park MM 103.4 Ocean	Approved	04/16/2016	06/07/2016		N/A	Application submitted Wk of 160627		
Largo Road & Grassy Rd (approved for Grassy)	Largo Sound Park MM 103.4 Ocean	Approved	04/16/2016	06/07/2016		N/A	Application submitted Wk of 160627		

THIS IS FY 17-18: 161114 None of the Phase 6 Fire Hydrants require FDOT approval; 160919 The hydrant list was submitted to FKAAs to determine location feasibility.	SUB DIVISION	FKAAs APPROVED HYDRANT LOCATION	DATE TO ENGINEERING FOR DRAWINGS	ENGINEERING DRAWINGS COMPLETE	DATE TO FDOT APPROVAL (if Required)	FDOT PERMIT APPROVAL	FKAAs UTILITY PERMIT (Good for 1 year)	DATE TO CONTRACTOR FOR INSTALLATION	COMPLETE
Mangrove Lane (Inside Paradise Point)- Feasible	Paradise Point	Yes							
Mangrove Lane (Middle) Feasible	Paradise Point	Yes							
Mangrove Lane (Entrance to Paradise Point) Feasible	Paradise Point	Yes							
Lake Surprise & Plantation Road-Feasible on Lake Surprise Blvd & South side of Plantation Rd. Not feasible on North side of Plantation	Lake Surprise	Yes							
Plantation & Upper Matecumbe Road- Feasible on Both Streets	Lake Surprise	Yes							
Largo Road & Long Key Road (Beginning of road) Feasible on Both Streets	Lake Surprise	Yes							
Largo Road & Long Key Road (End of the road)- Not Feasible at end of Long Key Road-4" wm starts at Lot 7 & 38 / Feasible anywhere south of those lots	Lake Surprise	Yes							
Largo Road and Grassy Road Feasible on Largo Road & North side of Grassy Rd. Not feasible on South side of Grassy Road	Lake Surprise	Yes							
Grassy Road (End of the street) Not Feasible at end of Grassy Road-4" wm starts at Lot 7 / Feasible anywhere south of that lot	Lake Surprise	Yes							
Oakwood Avenue & Linda Drive Feasible on Both Streets	Largo Hi-Land	Yes							
Stillwright Way and North Drive (Corner)	Stillwright Point	Yes							
Blackwater Lane & Coral Way (Corner) Feasible on Blackwater. Not feasible on Coral.	Stillwright Point	Yes							
N. Blackwater Lane & Sexton Way Feasible on N Blackwater. Not feasible on Sexton Way.	Stillwright Point	Yes							
N. Blackwater Lane & South Drive Feasible on N Blackwater. Not feasible on South Drive.	Stillwright Point	Yes							
N. Blackwater Lane (about ½ down add a second hydrant street is so long) Feasible on N Blackwater.	Stillwright Point	Yes							